

SCALE: 1/2" = 1"

## **SPECIFICATIONS:**

UNIT SHALL BE CONSTRUCTED OF 6063-T5 ALUMINUM EXTRUSION HAVING MINIMUM WALL THICKNESS OF .063. UNIT SHALL BE NEATLY FORMED AND FABRICATED WITH ALL JOINTS AND SEAMS COMPLETELY WELDED BY HELI-ARC PROCESS TO ENSURE MAXIMUM STRENGTH AND WATER TIGHTNESS, ACRYLIC PLASTIC DOME SHALL BE OF A THICKNESS AND CONFIGURATION TO CONFORM WITH U.B.C. REQUIREMENTS AND AAMA SPECIFICATIONS. UNIT SHALL BE SUPPLIED TO JOB READY FOR INSTALLATION.

CALIFORNIA STATE FIRE MARSHAL APPROVAL NO. 4350-054 SEE I.C.B.O. ES APPROVAL NO. 1998 CITY OF LOS ANGELES RESEARCH REPORT NO. RR-2708

Lane – Hire MANUFACTURING CORP.  2820 El Presidio Street, Carson, California 90749 (323) 636-2324 - FAX (310) 604-3395		
JOB		SHEET
ARCH.		OF
CONTR.		DIVIO NO
SUB. CONTR.		DWG. NO.
DRAWN BY -	DATE:	SQR.